

MAINE TURNPIKE AUTHORITY

ADDENDUM NO. 2

CONTRACT 2024.07

BRIDGE REPAIRS

ST. LAWRENCE & ATLANTIC OVERPASS (MM 74.50)

BLACKSTRAP ROAD OVERPASS (MM FS0.40)

MCRR OVERPASS (EB/WB) (MM FS0.50/FS0.51)

GRAY ROAD (ROUTE 26 & 100) UNDERPASS (MM FS0.70)

Questions:

The following are questions submitted to the Maine Turnpike Authority in writing. Answers to the questions are noted. Bidders shall utilize this information in preparing their bid.

Question 1: Would the MTA consider changing the completion dates for the various bridge locations?

Response: *The completion date at the St. Lawrence & Atlantic Overpass and Gray Road (Route 26 & 100) Underpass is changed to November 21, 2025. The substantial completion date at these locations is changed to October 31, 2025. The dates for the MCRR Overpass and Blackstrap Road Overpass are unchanged.*

Question 2: What is required for the removal of the existing membrane at the St. Lawrence & Atlantic Overpass? Can it be completed with bead blasting?

Response: *The removal of the high performance membrane shall be completed in accordance with Special Provision 202 REMOVING STRUCTURES AND OBSTRUCTIONS (Removing Existing Pavement and High Performance Waterproofing Membrane). The contractor may use bead blasting for final cleanup of the residual membrane and preparation of the concrete surface but may not be used as the primary method of removal. An alternate mechanical method shall be utilized for the primary removal of the high performance membrane.*

Make the following changes to the bid documents:

In the Contract Documents, Special Provision Section 107.1 on page SP-10, in the first bullet point under “St. Lawrence & Atlantic Overpass and Gray Road (Route 26 & 100) Underpass” **CHANGE** November 22, 2024 to November 21, 2025.

In the Contract Documents, Special Provision Section 107.1 on page SP-10, in the second bullet point under “St. Lawrence & Atlantic Overpass and Gray Road (Route 26 & 100) Underpass” **CHANGE** November 1, 2024 to October 31, 2025.

Note: The above items shall be considered as part of the bid submittal.

The total number of pages included with this addendum is two (2).

All bidders are requested to acknowledge the receipt of the Addendum No. 2 by signing below and faxing this sheet to Nate Carll, Purchasing Department, (207) 871-7739. Bidders are also required to acknowledge receipt of this Addendum No. 2 on Page P-6 of the bid package.

Business Name

Print Name and Title

Signature

Date

April 12, 2024

Very truly yours,

MAINE TURNPIKE AUTHORITY

Purchasing Manager
Maine Turnpike Authority