

MAINE TURNPIKE AUTHORITY

ADDENDUM NO. 1

CONTRACT 2018.21

INTERSTATE 195 CULVERT LININGS
SACO, MAINE

Make the following changes to the bid documents:

In the Contract Documents, Notice to Contractors, Page N-1, **REMOVE** the following sentences in the first paragraph: “Bids will be accepted from Contractors prequalified by the Maine Department of Transportation for Bridge or Highway Construction Projects. All other bids may be rejected.” Make this change in pen and ink.

Questions:

The following are questions submitted to the Maine Turnpike Authority in writing. Answers to the questions are noted. Bidders shall utilize this information in preparing their bid.

Question 1: Will the Maine Turnpike Authority accept solid wall HDPE liners (SnapTite) as an alternate to the liner?

Response: *The project permitting applications are based on the use of thin-walled cured-in-place pipe (CIPP) linings. The use of a solid wall HDPE or similar liners will not be an acceptable alternative.*

Attachments

- None

Note: The above items shall be considered as part of the bid submittal.

The total number of pages included with this addendum is two (2).

All bidders are requested to acknowledge the receipt of the Addendum No. 1 by signing below and faxing this sheet to Nate Carll, Purchasing Department, (207) 871-7739. Bidders are also required to acknowledge receipt of this Addendum No. 1 on Page P-3 of the bid package.

Business Name

Print Name and Title

Signature

Date

July 16, 2018

Very truly yours,

MAINE TURNPIKE AUTHORITY

Purchasing Manager
Maine Turnpike Authority