

**MAINE TURNPIKE AUTHORITY**

**ADDENDUM NO. 1**

**CONTRACT 2024.16**

**SLOPE AND DRAINAGE REPAIRS**

**MM 11.4 TO 51.9**

**The following changes are made to the CONTRACT DOCUMENTS:**

**PROPOSAL SHEETS:**

Remove page P-2 and replace with the attached.

**SPECIFICATIONS:**

Intentionally left blank.

**PLANS:**

Make a pen and ink change to the Estimated Quantities of sheet number C-1. Change Item 620.58 Erosion Control Geotextile to have a quantity of 375 SY. Change Item 629.05 Hand Labor, Straight Time to have a quantity of 80 HR.

**QUESTIONS:**

Q1: At STA 2587+50 there appears to be 3 Catch Basin, which is being replaced?

A1: The second catch basin, in the center of the median, is to be replaced. The basin will be marked in the field with spray paint reading "Con. 2024.16 replace" with an arrow identifying the basin.

Q2: There are multiple locations where guardrail will need to be removed and replaced, light clearing, and temp egress will need to be installed and removed to facilitate the called-out repairs. How are these to be paid?

A2: Guard rail R/R and temp egress shall be incidental to Item 659.1 Mobilization. Clearing (including any work done with a chainsaw) shall fall under Item 629.05 Hand Labor, Straight Time.

Q3: The MTA will only facilitate 4 shift per week of TC, Monday thru Thursday Nights, per the spec in many Locations. Will the MTA consider working Sunday evening as well to facilitate a 5-shift work week?

A3: No.

**Notes:** The above items shall be considered as part of the bid submittal.

The total number of pages included with this addendum is   3  

All bidders are requested to acknowledge the receipt of the Addendum No. 1 by signing below and faxing this sheet to Nate Carll, Purchasing Department, MTA at 207-871-7739. Bidders are also required to acknowledge receipt of this Addendum No. 1 on Page P-7 of the bid package.

\_\_\_\_\_  
Business Name

\_\_\_\_\_  
Print Name and Title

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Date

Very truly yours,  
MAINE TURNPIKE AUTHORITY

\_\_\_\_\_  
Nathanial Carll  
Purchasing Manager  
Maine Turnpike Authority

ITEM NO.	DESCRIPTION	UNIT	QUANTITY TOTAL	Unit Prices in Numbers		Bid Amount in Numbers	
				Dollars	Cents	Dollars	Cents
203.25	Granular Borrow	CY	160				
403.21	Hot Mix Asphalt 9.5 mm	TON	9				
603.155	12" RCP Class III	LF	48				
603.159	12" Culvert Pipe Option III	LF	60				
603.175	18" RCP Class III	LF	32				
603.195	24" RCP Class III	LF	64				
603.28	Concrete Collar	EA	10				
604.24	Catch Basin Type F4	EA	3				
610.08	Plain Rip Rap	CY	180				
613.319	Erosion Control Blanket	SY	1,900				
615.07	Loam	CY	80				
618.1401	Seeding Method Number 3	UNIT	9				
619.1202	Temporary Mulch	LS	1				
619.1401	Erosion Control Mix	CY	42				
620.58	Erosion Control Geotextile	SY	375				
629.05	Hand Labor, Straight Time	HR	80				
631.12	All Purpose Excavator (including operator)	HR	40				
631.172	Truck - Large (including operator)	HR	40				
631.36	Foreman	HR	40				
656.5	Baled Hay, in place	EA	9				
656.632	30-inch Temporary Silt Fence	LF	350				
659.1	Mobilization	LS	1				
<b>Total:</b>							